

# MODEL SEG-9 - Supply Performance Data

5/16" Diameter Holes on 7/16" Stg. Centers

Nominal Size		Nom Duct Area, ft <sup>2</sup>	Core Vel, fpm	200	300	400	500	600	700
W	H								
Width	Height		Ps	0.01	0.02	0.04	0.06	0.09	0.12
6"	6"	0.25	CFM	30	50	60	80	90	110
			NC	<20	<20	<20	22	28	32
			Throw	2   3   7	4   6   11	5   7   12	6   9   14	7   10   15	8   12   17
8"	8"	0.44	CFM	60	90	130	160	190	220
			NC	<20	<20	<20	25	31	36
			Throw	3   5   10	5   7   15	7   11   18	9   13   20	10   15   22	12   17   24
10"	8"	0.56	CFM	80	120	160	210	250	290
			NC	<20	<20	20	26	32	37
			Throw	4   6   11	6   9   17	8   11   20	10   15   23	12   18   25	14   19   27
10"	10"	0.69	CFM	110	160	210	270	320	370
			NC	<20	<20	21	28	33	38
			Throw	5   7   14	7   10   20	9   13   23	11   17   26	13   20   29	15   22   31
12"	12"	1.00	CFM	160	240	320	400	480	560
			NC	<20	<20	23	29	35	40
			Throw	5   8   16	8   12   24	11   16   29	14   20   32	16   24   35	19   27   38
14"	14"	1.36	CFM	230	340	450	560	680	790
			NC	<20	<20	24	31	36	41
			Throw	7   10   20	10   15   29	13   19   34	16   24   38	20   29   42	23   32   45
18"	14"	1.75	CFM	300	440	590	740	890	1040
			NC	<20	<20	25	32	38	42
			Throw	8   11   23	11   17   33	15   22   39	19   28   44	22   33   48	26   37   52
18"	18"	2.25	CFM	390	580	780	970	1170	1360
			NC	<20	<20	26	33	39	43
			Throw	9   13   26	13   19   38	17   26   45	21   32   50	26   38   55	30   42   59
20"	20"	2.78	CFM	490	730	980	1220	1460	1710
			NC	<20	<20	27	34	40	44
			Throw	10   14   29	14   21   43	19   29   50	24   36   56	28   43   62	33   47   67
24"	24"	4.00	CFM	720	1080	1440	1800	2160	2520
			NC	<20	20	29	36	41	46
			Throw	12   17   35	17   26   52	23   35   61	29   43   68	35   52   75	41   57   81
32"	32"	7.11	CFM	1310	1970	2630	3280	3940	4600
			NC	<20	23	32	38	44	49
			Throw	16   23   47	23   35   70	31   47   83	39   59   92	47   70   101	55   77   109

Data determined in accordance with ANSI/ASHRAE Standard 70-1991

Data based on Actual Neck Size = Nominal Neck Size - 1/4"

Ps - Static Pressure, inches w.g.

Throw - Distance, in feet, to terminal velocities of 150,100,50 fpm, respectively.

NC - Noise Criteria based on room attenuation of 10 dB

For Return use, -Ps = Ps (above) x 1.2, NC = NC (above) +2



**KEES INCORPORATED**  
400 S. Industrial Dr.  
Elkhart Lake, WI 53020

Phone: (920) 876-3391  
Fax: (920) 876-3065  
Website: www.kees.com